

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-1417:100

Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Lloyd Industries, Inc., 231 Commerce Dr., Montgomeryville, PA 18936
Contact: William P. Lloyd (215) 412-4445 Fax (215) 412-4409*

DESIGN: Model UL75 with suffix -A, -B, -C, or -D, curtain type fire dampers with 22 ga., 2-5/8" wide galvanized steel interlocking blades in a 22 ga. galvanized steel frame.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as a 1½-hour fire-rated damper. Approved for installation in the vertical position in rectangular or square heating ducts, or in wall openings without ducts not exceeding 59-3/4" in width and 59-3/4" in height when mounted individually, or 119-5/8" in width and 119-5/8" in height when mounted in multiple.

NOTE: Leakage rating not evaluated. Refer to Category 3230 for listed leakage dampers.

*Rev. 12-29-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JULY 13, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager